

Product Recall

Martindale/Drummond Test Lamp MTL10/15/20/20B Mk3		
Aspect	Details	
Images		
PSD Number	2410-0004	
Product Type	Hand tools – Test lamp	
Product Identifiers	Brand: Martindale/Drummond Sales period: The affected products were sold from 2023 onwards. Please refer to Annex A on page 2 for full details on the affected products	
Product Description	Various models of the Martindale / Drummond MTL10 / 15 / 20 / 20B Mk3.	
Country of Origin	Philippines	
Counterfeit	No	
Risk Level	Not provided	
Risk Type	Electric shock	
Risk Description	The affected models present a risk of electric shock because of an intermittent indication fault. The intermittent fault could have serious safety implications if the product is used to prove circuits are dead, and lead to electric shocks. This product does not meet the requirements of the General Product Safety Regulations 2005.	
Corrective Measures	The product has been recalled from end users. Consumers are advised to immediately stop using the unit if the serial number falls within the affected range. Units with S/No 321xxxxxxx and higher are not subject to recall. Contact Martindale Electric support for advice on 01923 441717. For more information on the recall please access further details on the Tester site at: https://www.tester.co.uk/blog/electrical/product-recall-martindale-drummond-mtl10-15-20-20b-mk3/	
Online Marketplace	N/A	
Notifier	Local Authority Trading Standards	

The OPSS Product Safety Alerts, Reports and Recalls Site can be accessed at the following link: https://www.gov.uk/guidance/product-recalls-and-alerts



Product Recall

Annex A - Affected models

Product name	Product code
MTL10 S	No 309xxxxxxx-317xxxxxxx
MTL15 S	No 309xxxxxxx-315xxxxxxx
MTL20 S	No 313xxxxxxx-314xxxxxxx
MTL20B S	No 314xxxxxxx